

AENOR

AENOR Product Certificate Conduit systems for cable management



030/002328

AENOR certifies that the organization

PLÁSTICOS REVI TUBOS, S.A.

registered office CR CASTRO DE BEIRO, 25 32001 OURENSE (España)

supplies Conduit systems buried underground for cable management

in compliance with UNE-EN 61386-1:2008 (EN 61386-1:2008)
UNE-EN 61386-1:2008 ERRATUM:2010
UNE-EN 61386-24:2011 (EN 61386-24:2010)

References Specified in Annex to the Certificate

Production site CR DE BARRA DE MIÑO, CL REGUENGA, 24 32950 RIVELA-COLES
(Ourense - España)

Certification scheme In order to grant this Certificate, AENOR has tested the product and has verified the quality system implemented for its manufacture. AENOR performs these tasks periodically while the Certificate has not been cancelled, in accordance with Specific Rules RP 030.12.

This certificate supersedes 030/002328, dated 2013-12-16

First issued on 2013-04-02
Modified on 2017-11-15
Validity date 2021-04-02

Rafael GARCÍA MEIRO
Chief Executive Officer

Original Electronic Certificate

AENOR

AENOR Product Certificate Conduit systems for cable management

030/002328

Annex to Certificate

Trade mark: REVI

Type Ref.	Type of conduit	Nominal diameter	Minimum inside diameter	Classification codes	Colour	Accessories	Additional information
REVI DOBLE PARED BARRAS	Non metallic	63-90-110-125-160-200-250 mm.	47-67-82-94-120-150-188 mm.	450 N; Normal; Rígido ; IP54 (1)	Yellow, red, orange, green, violet, blue.	Sleeves ; 63-90-110-125-160-200-250 mm.	Polyethylene
REVI DOBLE PARED ROLLOS	Non metallic	40-50-63-75-90-110-125-160-200 mm.	30-27-47-56-67-82-94-120-150 mm.	450 N; Normal; Curvable; IP54 (2)	Yellow, red, orange, green, violet, blue.	Sleeves ; 40-50-63-75-90-110-125-160-200 mm.	Polyethylene

- (1) Resistance to compression. Type 450 N.
Resistance to impact: Normal.
Resistance to bending: Rigid.
External influences: IP54
Resistance to flame propagation: Flame propagation
- (2) Resistance to compression. Type 450 N.
Resistance to impact: Normal.
Resistance to bending: Pliable.
External influences: IP54
Resistance to flame propagation: Flame propagation

First issued on 2013-04-02
Modified on 2017-11-15
Validity date 2021-04-02

Original Electronic Certificate

AENOR INTERNACIONAL S.A.U.
Génova, 6. 28004 Madrid. España
Tel. 91 432 60 00.- www.aenor.com

Product certification body accredited by ENAC, number 01/C-PR275